

## **SAN MARIN H.S. – STEM & PAC BUILDINGS - BID CLARIFICATION #5**

### **STEM Building**

1. See attached clarification letter from mechanical engineer (Costa Engineers). Please make corrections to your plan sheets as noted by mechanical engineer. Also see revised controls specifications for STEM Building

#### **Subcontractor RFI's:**

- 1) Glazing Subcontractor - Upon reviewing the plans and specs on Stem Bldg, Room # 106 storefront Type H calls out for 60 min fire rated opening. However, there are no specs for fire rated storefronts. Please advise.
- 1) Architect Response - Window Type H (Room 106) should be changed from aluminum storefront to hollow metal, and maintain the 60 minute fire rating. Window Type H at Room 101 should remain as aluminum storefront.

### **PAC Building**

No changes