



# COSTA ENGINEERS INC.

## Bid Clarification

3274 Villa Lane, Napa, CA 94558-3085 ph: 707-252-9177 fax: 707-252-6473

**Lyanne Schuster**

**CEI BC 05**

**QKA**

**636 Fifth Street**

**Santa Rosa, CA 95404**

From: Chris Del Core

Date: May 10, 2019

Regarding: San Marin HS STEM Building (#1682.00)

---

**All modifications, changes and additions listed in this addendum, the work included, and associated items necessary to complete such work in accordance with the original construction documents shall be included in the contract documents for the referenced project.**

---

### DRAWINGS

Sheet M1.1: Heat Pump Schedule; Revise Heat Pump Schedule as follows: HP2 and HP3 shall each be REYQ 216, as shown in the piping diagrams on sheet M5.1.

Sheet M5.2: Delete diagrams A & B/M5.2. VRV systems lose efficiency and functionality using 3rd party thermostats, therefore the iTouch controller will be used as specified in attached controls specification. For Economizer control, use a JADE controller at each fan coil system as required.

### SPECIFICATIONS

**DELETE** Specification Section 23 0923 - Energy Management System for HVAC in its' entirety. Replace with Specification Section 23 0900 - Controls for HVAC. (Attached)

Attachment: Section 23 0900